



Ref. Certif. No.

PL 2 0594

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fixed, flush-type, single socket-outlets,
with side earthing contact.

Name and address of the applicant

Z.S.E. „OSPEL” Spółka Akcyjna
Wierbka, ul. Główna 128
42-436 Pilica, Poland

Name and address of the manufacturer

Z.S.E. „OSPEL” Spółka Akcyjna
Wierbka, ul. Główna 128
42-436 Pilica, Poland

Name and address of the factory

Z.S.E. „OSPEL” Spółka Akcyjna
Wierbka, ul. Główna 128
42-436 Pilica, Poland

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

16 A; 250 V~; IP20, IP44

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

Series ARIA,
type: 2119, variation:
GP-1US, GP-1US/m, GP-1USP, GP-1USP/m;
type: 2121, variation:
GPH-1US, GPH-1US/m, GPH-1USP, GPH-1USP/m

Additional information (if necessary may also be
reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found
to be in conformity with

IEC 60884-1:2002+AMD1:2006+AMD2:2013

As shown in the Test Report Ref. No. which
forms part of this Certificate

LS-19.033/19.003/II/E
LS-19.033/19.003/II/E

This CB Test Certificate is issued by the National Certification Body



SEP - BBJ
ul. M. Pożaryskiego 28
04-703 Warszawa
POLAND

Phone:

+48 22 812 69 38

Fax:

+48 22 815 65 80

e-mail:

bbj@bbj.pl



Date: 2019-09-09

Signature: Andrzej Rybski

A. Rybski



Ref. Certif. No.

PL 2 0594

Additional information (if necessary)

Date: 2019-09-09



A. Rybski

Signature: Andrzej Rybski